

Mr N J Thurstan DMS MCIEH

Assistant Director
(Environment, Health, & Regulatory Services)

Reference:
Please ask for:

Anker Moor County Primary School
Rene Road
Tamworth
B77 3NW

03 July 2009

Dear

**Regulation (EC) No 852/2004 applied by Regulation 17(1) of the Food Hygiene (England) (No 2) Regulations 2005 (Other legislation and relevant parts of EC 852 are specified below as applicable)
Anker Moor County Primary School Rene Road Tamworth B77 3NW**

I write to confirm the inspection of the above mentioned premises on 25th June 2009 during which I was accompanied by XX. I am pleased to report that the premises were found to be generally satisfactory and I trust the high standards will be maintained in the future.

The following points were noted that require attention:

1. The flaking paintwork to the ceiling above the sterilising sink requires removing and the area re decorating.
2. Accumulations of dust were noted to the window mounted vent axia extractor fan above the sterilising sink.

Please note that subject to the Data Protection Act, details of inspections may be divulged to members of the public under the Freedom of Information Act 2000.

I enclose your "ratemyplace" certificate and associated inspection summary. I recommend that you display the Certificate in a prominent position. Please note that parts of this inspection report will appear on the following website www.ratemyplace.org.uk.

Should you require any further advice or assistance please contact this unit.

Yours faithfully